

0033409



LOW RISK

GHANA NATIONAL FIRE SERVICE



FIRE CERTIFICATE

This is to certify that

house number _____ of SUBRI, W/R _____ has been issued
with Fire Certificate for use as PLACE OF WORK (OFFICE/WORKSHOP) GHANA RUBBER
ESTATE LIMITED

Having upon inspection satisfied the following requirement as Fire Safety:

Means of Escape

Type	Number	Location
a) MAIN EXIT	A O D	A O D
b) GFN	1	
c)		
d)		

Fire Fighting Equipment

Type	Number	Location
a) CO ₂ (5KG)	2	
b) DP ² (6KG)	3	
c)		
d)		

Fire Hydrant/Source of Water Supply

HYDRANT - NIL
ALTERNATIVE SOURCE OF WATER - WATER TANK (4,500 LITRS.)

Warning Device(s)

Type	Number	Location
a) DS (BATTERY)	5	
b)		
c)		
d)		

WC14190L

THIS CERTIFICATE IS VALID FOR TWELVE MONTHS

Dated this 13TH day of SEPTEMBER, 2021

DGFO DANIELLA MAWUSI NTOW SAPONG

for: CHIEF FIRE OFFICER



In case of reply the number and date of this letter should be quoted



**Ghana National Fire Service
Headquarters
GPS Address: GA-238-0816
P. O. Box 4129
Accra - Ghana
Tel: 0302 772 446
Fax: 0302 772 451**

NFS/.SAF.D/R21.WC/VOL.VII/ *SS*
My Ref: No.....

Your Ref: No.....

7
.....DECEMBER, 2021.....

THE MANAGER
GHANA RUBBER ESTATES LIMITED
SUBRI, W/R

RENEWAL – FIRE CERTIFICATE (WC14190 L)

1. The under listed documents on your premises (Office/Workshop) have been inspected by an authorized Fire Inspector for the renewal of your Fire Certificate.
 - i) Previous Fire Certificate
 - ii) Log book
2. Re- inspection of your premises shows that:-
 - i) Fire extinguishers installed have been serviced
 - ii) Record of test on fire extinguishers, fire alarm and training entered in the log book has been checked (where appropriate).
3. In addition to the above, you need to provide the following information before the next renewal date:
 - i) Provide the location of the nearest hydrant to the premises
 - ii) Evidence of compulsory Fire Insurance Certificate
 - iii) The quantities of fire facilities installed on premises
 - iv) Confirmation of the type of fire detection and warning system installed (i.e. Battery or Electrical)
4. Management shall ensure that Log book entries are made and installed fire facilities are maintained by a competent Fire Protection Service Contractor/Provider.
5. Your Fire Certificate is hereby renewed and expires in September, 2022.
6. Attached is the new Fire Certificate No. 0033409.

NB:

- FAILURE TO DISPLAY THE FIRE CERTIFICATE IS AN OFFENCE
- FAILURE TO RENEW AN EXPIRED CERTIFICATE IS AN OFFENCE

**DANIELLA MAWUSI NTOW SAPONG
DCFO
DIRECTOR FIRE SAFETY
for: CHIEF FIRE OFFICER**